

Fluid Equipment Co., Inc.

70 Mt. Creek Trail
Social Circle, GA 30025

770-787-0551 F8052 Cell 404-386-1499

donmcpeak@att.net

These are (3) Three 8" Pump Control Valves with standard pump control features; open and closing speed, check valve feature, limit switch relay motor control, solenoid, etc. Because of the extreme dirty water being pumped, Micron Filters were used, instead of Y-Strainers. The filter run is very long. This installation was put in before we started going to full ported large solenoids. The newer full ported solenoids are not nearly as sensitive to suspended particles in the water.

